
Latching Relay UG 8851






Product Description

The latching relay UG8851 is designed with a wide AC/DC nominal voltage range. Short pulses of several miliseconds switch the relay into a defined position. To change the contact position only low power is necessary. No energy is necessary to hold the relay in ON-state. This is energy efficientand reduces the powerdissipation of the unit. On loss of power the relay stays in it's defined position. The special feature of forcibly guided contacts (IEC 61810-3) allows reliable monitoring of the contact state.

Function Diagram



Your Advantage

- Large voltage range AC/DC 24 ... 240 V
- Protection against manipulation by sealable transparent cover over setting switches
- More contacts at small design
- Energy saving, no holding capacity neccessary

Features

- According to IEC/EN 61810-1
- With forcibly guided contacts according to IEC 61810-3
- With manual operation and contact position indication via control lever
- With impulse energization A1 A2
- With reset pulse B1 B2
- · 4 NC contacts, 4 NO contacts or 4 changeover contacts
- With pluggable terminal blocks for easy exchange of devices
- With coded terminal blocks
- Width 22.5 mm

Approvals and Markings



Application

Pulse conversion into a continuous function A pulse control (inputs side) leads to a continuous function (output side).

Function

The relay is operated either by voltage pulses or continuous voltage on the inputs A1-A2, B1-B2. When both coils are activated the contacts keep the state of the first energized coil. The 2 coil systems operate status driven. This means when both coils are energised and the first energised coil is deactivated the status of the contacts is inverted. On loss of voltage, the latching relay remains in it's las contact position.

Indication

yellow LED *A1: on, when control voltage A1/A2 connected


yellow LED B1: on, when control voltage B1/B2 connected

Notes


If coil A1-A2 / coil B1-B2 are controlled with DC, the terminals A1(+) and B1(+) have to be connected on the positive pole.

The device is available on request with customer specific RC element (Snubber Circuit) over the switching contact.

Circuit Diagrams



UG 8851.19



UG 8851.14

Connection Terminals

Terminal designation	Signal designation
A1(+), A2	Pulse excitation AC/DC
B1(+), A2	reset pulse AC/DC
13 to 44	4 forcibly guided NO contacts
51 to 82	4 forcibly guided NC contacts
11 to 44 (UG 8851.14)	4 forcibly guided C/O contacts

Technical Data

Input

Nominal voltage U_N: AC/DC 24 ... 240 V Voltage range: AC 0.8 ... 1.1 U_N DC 0.9 ... 1.15 U_N AC 24 V / 0.1 VA Nominal consumption: DC 24 V / 0.12 W

AC 230 V / 1.3 VA DC 230 V / 1.4 W

Max. consumption during switching operation

t_{ein} < 100ms: AC 24 V / 2.5 VA

DC 24 V / 3 W AC 230 V / 5.6 VA DC 230V / 4.3 W 50 ... 400 Hz

Nominal frequency: ±5% Frequency range: Min. pulse duration ${\rm ts_{_{\min}}}$, ${\rm tr_{_{\min}}}$ > 30 ms Min. on and off time tp_{min}: > 300 ms Permissible residual current: AC/DC < 4 mA

Output

Contacts:

UG 8851.19: 4 NO, 4 NC contacts UG 8851.14: 4 changeover contacts

Operate time of contacts: < 30 ms Release time of contacts: < 30 ms 6 A / 4 A / 3 A Thermal current I_{th}:

current via 2 / 3 / 4 contacts

Switching capacity

to AC 15

NO contacts: 3 A / AC 230 V IEC/EN 60 947-5-1 NC contacts: 2 A / AC 230 V IEC/EN 60 947-5-1

to DC 13: NO contacts: NC contacts:

2 A / DC 24 V IEC/EN 60 947-5-1 2 A / DC 24 V IEC/EN 60 947-5-1

Electrical life

IEC/EN 60 947-5-1 to AC 15 at 1 A, AC 230 V: 1 x 10⁵ switching cycles

3 000 switches/h at 50 % of the

switching capacity 0.5 x 106 switching cycles 1 000 switches/h at 100% of the

switching capacity

Permissible switching

frequency:

3 000 switching cycles / h

Short circuit strength max. fuse rating:

6 A gG/gL IEC/EN 60 947-5-1

10 x 10⁶ switching cycles Mechanical life:

General Data

Operating mode: Impulse- or continuous operation

Temperature range

- 20 ... + 60°C Operation: Storage: - 40 ... + 70°C < 2,000 m Altitude:

Clearance and creepace

distances

rated impulse voltage / pollution degree

Control (A1, A2; B1, B2) /

contacts: 6 kV / 2 IEC 60 664-1 IEC 60 664-1 Contacts / contacts: 4 kV / 2

EMC

Electrostatic discharge: IEC/EN 61 000-4-2 8 kV (air) HF irradiation IEC/EN 61 000-4-3, EN 50 121-3-2

80 MHz ... 1 GHz: 20 V / m 1 GHz ... 2.7 GHz: 10 V / m

Fast transients: 4 kV IEC/EN 61 000-4-4

Surge voltages

between

wires for power supply: 2 kV IEC/EN 61 000-4-5 IEC/EN 61 000-4-5 4 kV between wire and ground: Interference suppression: Limit value class B EN 55 011 HF-wire guided: 10 V IEC/EN 61 000-4-6

2 27.09.16 en / 773

Technical Data

Degree of protection:

 Housing:
 IP 40
 IEC/EN 60 529

 Terminals:
 IP 20
 IEC/EN 60 529

Housing: Thermoplast with V0-behaviour

to UL subject 94 **Vibration resistance:** Amplitude 0,35 mm

frequency 10...55Hz,IEC/EN 60 068-2-6 20 / 60 / 04 IEC/EN 60 068-1

Climate resistance: 20 / 60 / 04 Terminal designation: EN 50 005

Wire connection: Terminal blocks DIN 46 228-1/-2/-3/-4

with screw terminals

Cross section: 1 x 0.25 ... 2.5 mm² solid or stranded ferruled (isolated) or 2 x 0.25 ... 1.0 mm² solid or

stranded ferruled (isolated)

Insulation of wires or

sleeve length: 7 mm

Wire fixing: captive slotted screw M2,5

Fixing torque: 0,5 Nm

Mounting: DIN rail IEC/EN 60 715

Weight: 190 g

Dimensions

Width x height x depth: 22.5 x 110 x 120.3 mm

Classification to DIN EN 50155

Vibration and

shock resistance: Category 1, Class B IEC/EN 61 373

Protective coating of the PCB: No

Standard Type

UG 8851.19PS AC/DC 24 ... 240 V Article number: 0065644

Output: 4 NO contacts, 4 NC contacts

Nominal voltage U_N: AC/DC 24 ... 240 V

• Width: 22.5 mm

Ordering example

<u>UG 8851</u> <u>.19</u> <u>PS</u> <u>AC/DC 24 ... 240 V</u>

Nominal voltage
Type of terminals
PS (plug in screw):
pluggable terminal blocks
with screw terminals

with screv - Contacts

– Type

Option with Pluggable Terminal Block



Screw terminal (PS/plugin screw)

 \triangle

Safety Notes



Dangerous voltage.

Electric shock will result in death or serious injury.



Disconnect all power supplies before servicing equipment.

- Faults must only be removed when the relay is disconnected
- The user has to make sure that the device and corresponding components are installed and wired according to the local rules and law (TUEV, VDE, Health and safety).
- Settings must only be changed by trained staff taking into account the safety regulations. Installation work must only be done when power is disconnected.
- Observe proper grounding of all components

3 27.09.16 en / 773

E. DOLD & SÖHNE KG • D-78114 Furtwangen •	PO Box 1251 • Telephone (+49) 77 23 / 654-0 • Telefax (+49) 77 23 / 654-356